

MACON MIDDLE EAST FZE

E30-60-90-120-120/EW30-60-90-120



intertek
Total Quality. Assured.



This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

Certificate of Compliance

You have been awarded:
WH Service Mark 2014 for Category D - Door/frame Assemblies

Standards: EN 1634-1:2014+A1(2018)

Certificate number: WH120 – 34647101

Organization: Macon Middle East FZE
Shed 29#5, Al Hulaila Industrial Zone - FZ
P.O. Box 326046
Ras Al Khaimah
United Arab Emirates

Product: Forster Profilsysteme AG - Forster Presto - Fully Glazed Sliding Door Assembly - EN 1634-1
Spec ID: 46474
Fire Rating: 2 Hour Fire Rated, 1 Hour Fire Rating, 90 Minute Fire Rated, 30 Minute Fire Rated
Listing Information: See following page(s)

Certification body: Intertek Testing Services NA, Inc.
Initial registration: June 29, 2020
Date of expiry: December 31, 2025
Issue status: 6

Authorized By: 
Jean-Philippe Kayl, Director of Certification

Intertek Testing Services NA, Inc.
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA
Phone: 847-439-5667 Fax: 847-439-7320

www.intertek.com

SLIDING DOOR WITH INTEGRITY & RADIATION CONTROL

PROFILE	FORSTER PRESTO
GLASS	CONTRAFLAM LITE
RATING	E30-60-90-120 /EW30-60-90-120 / EI30
STANDARD	EN 1634-1

MACON MIDDLE EAST FZE

Al Hulaila Industrial Zone FZ

P.O. Box 326046, Ras Al Khaimah, UAE

Email:- info@macon-me.com

